



**NOTES:**

1. SPECIAL CIRCUMSTANCES MAY REQUIRE THE NEED FOR WATERTIGHT FRAMES, GASKETED OR BOLTED LIDS, ETC. AS DIRECTED BY THE CITY OF RENO. DETAILED PLANS OF ANY SPECIAL MANHOLE FRAMES AND/OR COVERS MUST BE APPROVED BY THE CITY ENGINEER.
2. DEETER FOUNDRY COVER AND FRAME #9020 OR APPROVED EQUAL.
3. THE UTILIZATION OF THIS FRAME AND COVER IN FLOOD SUSCEPTIBLE AREAS SHALL BE DETERMINED BY THE CITY ENGINEER.
4. FURNISHED WITH MACHINED HORIZONTAL BEARING SURFACE.
5. CAST GRAY IRON, ASTM A-48, CLASS 35B, NO PAINT.

NO.	REVISION	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION	RENO
1	LOGO MANHOLE	01/04	24" SANITARY SEWER MANHOLE FRAME & COVER	DRAWING NO.	R-214 (326)
				DATE	08/00
				PAGE	219
APPROVED BY:	G.S.	01/04			